

UL 827, Central-Station Alarm Services (April 23, 1999).

UL 1076, Proprietary Burglar Alarm Units and Systems (February 1, 1999).

(e) *American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE) standards.* The following ASHRAE standards are available from ASHRAE at ASHRAE Customer Service, 1791 Tullie Circle NE, Atlanta, GA 30329 or online at [www.ASHRAE.org](http://www.ASHRAE.org):

ANSI/ASHRAE 55-1992, Thermal Environmental Conditions for Human Occupancy.

ANSI/ASHRAE 62-1989, Ventilation for Acceptable Indoor Air Quality.

(f) *American National Standards Institute (ANSI) standards.* The following ANSI standards are available from the American National Standards Institute, 11 West 42nd St., New York, NY 10036:

ANSI/NAPM IT9.18-1996, Imaging Materials—Processed Photographic Plates—Storage Practices.

ANSI/NAPM IT9.20-1996, Imaging Materials—Reflection Prints—Storage Practices.

ANSI/NAPM IT9.23-1996, Imaging Materials—Polyester Base Magnetic Tape—Storage.

ANSI/PIMA IT9.11-1998, Imaging Materials—Processed Safety Photographic Films—Storage.

ANSI/PIMA IT9.25-1998, Imaging Materials—Optical Disc Media—Storage.

[64 FR 67642, Dec. 2, 1999, as amended at 67 FR 79518, Dec. 30, 2002]

#### § 1228.226 Definitions.

The following definitions apply to this subpart:

*Auxiliary spaces* mean non-records storage areas such as offices, research rooms, other work and general storage areas but excluding boiler rooms or rooms containing equipment operating with a fuel supply such as generator rooms.

*Commercial records storage facility* has the meaning specified in § 1220.14 of this chapter.

*Existing records storage facility* means any records center or commercial records storage facility used to store records on January 2, 2000, and that has stored records continuously since that date.

*Fire barrier wall* means a wall, other than a fire wall, having a fire resistance rating, constructed in accordance with NFPA 221 (1994), Standard for Fire

Walls and Fire Barrier Walls, Chapter 4.

*Licensed fire protection engineer* means a licensed or registered professional engineer with a recognized specialization in fire protection engineering. For those States that do not separately license or register fire protection engineers, a licensed or registered professional engineer with training and experience in fire protection engineering, operating within the scope of that licensing or registration, who is also a professional member of the Society of Fire Protection Engineers.

*Must* and *provide* mean that a provision is mandatory.

*New records storage facility* means any records center or commercial records storage facility established or converted for use as a records center or commercial records storage facility on or after January 3, 2000.

*Permanent record* has the meaning specified in § 1220.14 of this chapter.

*Records center* has the meaning specified in § 1220.14 of this chapter.

*Records storage area* means the area containing records that is enclosed by four fire walls, the floor, and the ceiling.

*Records storage facility* has the meaning specified in § 1220.14 of this chapter.

*Sample/select records* means records whose final disposition requires an analytical or statistical sampling prior to final disposition authorization, in which some percentage of the original accession will be retained as permanent records.

*Should* or *may* means that a provision is recommended or advised but not required.

*Temporary record* has the meaning specified in § 1220.14 of this chapter.

*Unscheduled records* has the meaning specified in § 1220.14 of this chapter.

[64 FR 67642, Dec. 2, 1999; 64 FR 68946, Dec. 9, 1999]

#### FACILITY STANDARDS

#### § 1228.228 What are the facility requirements for all records storage facilities?

(a) The facility must be constructed with non-combustible materials and